

TECHNICAL LETTER— ADHESION TO ADVANTECH ENGINEERED WOOD PRODUCTS

Jiffy Seal Ice & Water Guard HT™ and Jiffy Seal Butyl Ice & Water Guard HT™ have been tested for peel adhesion when applied to the AdvanTech® roof sheathing products. The testing was conducted per ASTM D3330, Method F. Jiffy Seal Ice & Water Guard HT™ and Jiffy Seal Butyl Ice & Water Guard HT™ meet and/or exceed competitors products tested per the same method and exceeds the minimum industry standard for peel adhesion (1.5 pli).

Protecto Wrap Company recommends following the manufacturers recommendations when installing a complete waterproofing system on top of the AdvanTech® roof sheathing.

Protecto Wrap Company recommends testing for adhesion prior to full application to ensure adequate adhesion.

AdvanTech® is a registered product manufactured by Huber Engineered Woods and is not affiliated with Protecto Wrap Company

Protecto Wrap Company provides the information here based on knowledge and data considered to be true and accurate at the time of publication, and is offered for the user's consideration, verification and investigation. Protecto Wrap Company does not warrant the results to be obtained or the appropriateness of the offering for the user's particular project. It is the sole responsibility of the user to read and understand all statements, recommendations or suggestions regarding conditions of sale. No statement, suggestion or recommendation herein is intended for any use that could infringe on any copyright or patent. These products may be covered by patents or patents pending. Copyright 2008. Protecto Wrap Company

PROTECTO WRAP COMPANY

1955 South Cherokee Street Denver, CO 80223 1-800-759-9727 (303) 777-3001 Fax (303)777-9273 www.protectowrap.com